



ACIA
Airborne Contamination Identification
Associates Ltd.

Airborne Contamination Identification Associates Ltd.

Certifies that

New Concept Technology

320 Busser Road

PO Box 0297

Emigsville PA 17318-0297

"Medical Assembly Cleanroom" meets and exceeds ISO 14644-1

Class 5 on 0.3, 0.5, & 5.0 micron for airborne particulate cleanliness **at rest.**

"Medical Assembly Cleanroom" meets and exceeds ISO 14644-1

Class 6 on 0.3 0.5, 1.0 & 5.0 micron for airborne particulate cleanliness **in production**

Certificate # 08-30-2024

Expires: September 01, 2025

Certified By:

Randall R. Leaman C.I.A.Q.P.

"Certified Indoor Air Quality Professional"



3430 WOODBRIDGE CIRCLE YORK PA 17406 – PH: 717-767-1850 FAX: 717-717-767-1860

New Concept Technology
320 Busser Rd
Emigsville, PA 17318
Attn: Tom Bauchman

August 27, 2024

Re: Report of Medical Cleanroom Certification

Dates Sampled: August 14, 2024; in Production; August 15, 2024; At Rest.

Sample By: Randy Leaman

Equipment Used:

Model: Met One Instruments GT526S, Serial R16936
Calibrated: October 2023
Particle Sizes: 0.3, 0.5, 1.0, 5.0 Micron

Quantity of Samples Collected in Production 08/14/2024:

22 Samples in Clean Room; Class 6 on 0.3, 0.5, 1.0 & 5.0 Micron
2 Sample in the Supervisors Office; Class 7 on 0.5 & 1.0 Micron
2 Samples in the Gowning Room; Class 8 on 0.5 & 1.0 Micron

*Note: One press was running

Quantity of Samples Collected at Rest 08/15/2024:

22 Samples in Clean Room; Class 5 on 0.3, 0.5, 1.0 & 5.0 Micron
2 Sample in the Supervisors Office; Class 7 on 0.5, 1.0 & 5.0 Micron
2 Samples in the Gowning Room; Class 8 on 0.5, 1.0 & 5.0 Micron

Definition of “Operational” Statements

- Medical Assembly Cleanroom was + 0.023” wg positive pressure in relation to the shop area.

HEPA resistance was 0.26” water gauge

Note: Uncertainties related to the measurement process require that concentration data with no more than three significant figures be used in determining the classification level.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATIONS ASSOCIATES, LTD.

Randall R. Leaman
Randall R. Leaman C.I.A.Q.P

Our Certifications:

WBENC: Certified Women Owned Business (WBE)

Pennsylvania Home Improvement Contractor Registration Number: PA 059333

NADCA Certified Ventilation Systems Mold Remediators (CVSMR)

NADCA Certified Air Systems Cleaning Specialists (ASCS)

AEE – Certified Indoor Air Quality Professional (CIAQP)

ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)

Anabec: Certified Microbial Remediation Supervisor and Product Distributor (CMRS)

Carlisle Trained Applicators for RE-500 and RS-100

CO-STARs # 008-202